

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1335:103 Page 1 of 1

CATEGORY: Power Units

LISTEE: Altronix Corp., 140 - 58th Street, Building A-3W, Brooklyn NY 11220
Contact: Alan Forman (718) 567-8181 Fax (718) 567-9056

DESIGN: Models AL500UL-ADA and AL600UL-ADA,*AL602-UL-ADA Power-limited Indicating Circuit Power Supply. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: AL500UL-ADA: 120 VAC input, 12/24 VDC output, 4A
AL600UL-ADA: 120 VAC input, 12/24 VDC output, 6A
*AL602UL-ADA:115 VAC input, 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a power-limited indicating circuit power supply for use with separately listed compatible fire alarm control units and indicating devices. Authority having jurisdiction should be consulted prior to installation.

*REV. 09-06-2002 TR



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANK K. AREND, Senior Deputy
Program Manager